

# Energy performance certificate (EPC)

24, St. Peters Close  
DAVENTRY  
NN11 4SG

Energy rating

**D**

Valid until: **11 December 2023**

Certificate number: **8507-7922-1159-0640-2992**

Property type

Semi-detached house

Total floor area

38 square metres

## Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

## Energy rating and score

This property's current energy rating is D. It has the potential to be A.

[See how to improve this property's energy efficiency.](#)

| Score | Energy rating | Current     | Potential   |
|-------|---------------|-------------|-------------|
| 92+   | <b>A</b>      |             | 92 <b>A</b> |
| 81-91 | <b>B</b>      |             |             |
| 69-80 | <b>C</b>      |             |             |
| 55-68 | <b>D</b>      | 57 <b>D</b> |             |
| 39-54 | <b>E</b>      |             |             |
| 21-38 | <b>F</b>      |             |             |
| 1-20  | <b>G</b>      |             |             |

The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D  
the average energy score is 60

## Breakdown of property's energy performance

### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

| Feature              | Description                                 | Rating  |
|----------------------|---|---------|
| Wall                 | Cavity wall, as built, insulated (assumed)  | Good    |
| Roof                 | Pitched, 100 mm loft insulation             | Average |
| Window               | Fully double glazed                         | Average |
| Main heating         | Room heaters, mains gas                     | Good    |
| Main heating control | No thermostatic control of room temperature | Poor    |
| Hot water            | Electric immersion, off-peak                | Poor    |
| Lighting             | Low energy lighting in 17% of fixed outlets | Poor    |
| Floor                | Solid, no insulation (assumed)              | N/A     |
| Secondary heating    | Portable electric heaters (assumed)         | N/A     |

### Primary energy use

The primary energy use for this property per year is 316 kilowatt hours per square metre (kWh/m<sup>2</sup>).

---

## How this affects your energy bills

An average household would need to spend **£627 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £261 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2013** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

---

### Heating this property

Estimated energy needed in this property is:

- 3,938 kWh per year for heating
- 1,699 kWh per year for hot water

## Impact on the environment

This property's current environmental impact rating is D. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

### Carbon emissions

An average household produces 6 tonnes of CO<sub>2</sub>

This property produces 2.2 tonnes of CO<sub>2</sub>

This property's potential production 0.2 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

## Changes you could make

| Step   | Typical installation cost | Typical yearly saving |
|--|---------------------------|-----------------------|
| 1. Floor insulation                                  | £800 - £1,200             | £28                   |
| 2. Add additional 80 mm jacket to hot water cylinder | £15 - £30                 | £21                   |
| 3. Low energy lighting                               | £25                       | £19                   |
| 4. Condensing boiler                                 | £3,000 - £7,000           | £166                  |
| 5. Solar water heating                               | £4,000 - £6,000           | £27                   |
| 6. Solar photovoltaic panels                         | £9,000 - £14,000          | £244                  |
| 7. Wind turbine                                      | £1,500 - £4,000           | £21                   |

## Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

## More ways to save energy

Find ways to save energy in your home by visiting [www.gov.uk/improve-energy-efficiency](http://www.gov.uk/improve-energy-efficiency).

## Who to contact about this certificate

### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

|                 |  |
|-----------------|--|
| Assessor's name | Dale Hillery   |
| Telephone       | 01604 751902   |
| Email           | <a href="mailto:dalehillery@aol.com">dalehillery@aol.com</a> |

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

|                      |  |
|----------------------|--|
| Accreditation scheme | Elmhurst Energy Systems Ltd  |
| Assessor's ID        | EES/007044   |
| Telephone            | 01455 883 250  |
| Email                | <a href="mailto:enquiries@elmhurstenergy.co.uk">enquiries@elmhurstenergy.co.uk</a> |

### About this assessment

|                        |                       |
|------------------------|-----------------------|
| Assessor's declaration | No related party      |
| Date of assessment     | 10 December 2013      |
| Date of certificate    | 12 December 2013      |
| Type of assessment     | <a href="#">RdSAP</a> |

---